

DETERMINING SEWER ALLOCATION

Calculated according to Environmental Protection Rules (January 2005) Chapter 1 Wastewater System and Potable Water Supply Rules released by the State of Vermont, Agency of Natural Resources, Department of Environmental Conservation, Wastewater Management Division.

Required Sewer Allocation = (future design flow – existing design flow) * 0.80

Single Family Home

Design Flow (gpd gallons per day) * \$4.00/gpd = Allocation Cost

210 gpd * \$4.00/gpd = \$840.00

Multi Family Home

Number of Bedrooms	Design Flow (gpd)	Large System Multiplying Factor	Net Flow (gpd)	Cost per gpd	Total Price
2	280	0.8	224	\$4.00/gpd	\$896
3	420	0.8	336	\$4.00/gpd	\$1,344
4	490	0.8	392	\$4.00/gpd	\$1,568
5	560	0.8	448	\$4.00/gpd	\$1,792
6	630	0.8	504	\$4.00/gpd	\$2,016
7	700	0.8	560	\$4.00/gpd	\$2,240
8	770	0.8	616	\$4.00/gpd	\$2,464
9	840	0.8	672	\$4.00/gpd	\$2,688
10	910	0.8	728	\$4.00/gpd	\$2,912
11	980	0.8	784	\$4.00/gpd	\$3,136
12	1050	0.8	840	\$4.00/gpd	\$3,360
13	1120	0.8	896	\$4.00/gpd	\$3,584
14	1190	0.8	952	\$4.00/gpd	\$3,808

add 70 gpd for each extra unit